

2020 Holiday Curtailment

Program

Updated: 12/21/20

Shutdown Tuesday, December 22, 2020, 3:00 pm	Startup Monday, January 4, 2021 10:00 am
--	--

Team			
Num	Name	Office*	Cell Number
1	Bruce Chamberlain	EO	510-812-3711
2	Catherine Patton	EO	510-549-6472
3	Kume Wolde	EO	510-292-8100
4	Ahmed Hassani	EO	510-847-3100
5	U Yu Kyi	SE	510-812-2137
6	Raul Abesamis	EMS	510-812-0828
7	David Etayo - ALC	EMS	510-812-2130
8	Bricio Yuriar - Barrington	EMS	510-812-0831
9	Todd McFerren	ELEC	510-812-0853
	TBD	ELEC	

*EO = Energy Office SE = Stationary Engineer, PM EMS = Energy Management System ELEC = Electrical Shop

General Notes:

- 1 Safety first
- 2 Systems supporting fume hood, animal, or temperature controlled operations should NOT be turned off
- 3 **Setback heat exchangers/boilers to 140 degrees (minimum).**
- 4 Field verify that systems can be de-energized and shutdown
- 5 Where variations occur, notify leads and record differences
- 6 Notify leads of system shutdown and startup failures

Curtailment at regular times								
Building Name	Systems	Notes	EMS	Zone	Fans 19	HHW 19	Ltg 19	
UNIVERSITY	FANS, SETBACK HHW to 160		B	1	EMS	EMS		
WARREN (Office space)	AHU1, AHU2, Chiller		B	1	EMS	EMS		
CARLETO2000	FANS except AHU6 (SF26/EF35), AH5 (SF34/RF34)		B	1	EMS	Ex		
BECHTEL CNTR	FANS, SETBACK HHW		B	2	EMS	EMS		
HAVILAND	FANS		B	2	EMS	Ex		
HESSE	FANS, Setback HHW		B	2	EMS	EMS		
MCLAUGHLIN	FANS (SF-10,11, EF-3,29, 30), SETBACK HHW (incl for Hesse HX-16,17)		B	2	EMS	EMS		
CALVIN LAB	FANS, SETBACK HHW		B	3	EMS	EMS		
HAAS STU BLD	Fans, Setback HHW		B	3	EMS	EMS		
LAW	Fans, Setback HHW. EXCEPT for Rare Books (R235 and R236)		A/B	3	EMS	EMS		
MINOR ADDITN	Fans except AHU 1 and 4, EFs 1&2		A/B	3	EMS	Ex		
SIMON (Law)	FANS, Setback HHW EXCEPT R235 & R236 (Robbins Collection)		A/B	3	EMS	EMS		
MORGAN	SF11	SF11 serves auditorium	B	4	EMS	Ex		
CALIFORNIA	FANS, SETBACK HHW		B	5	EMS	EMS		
DOE LIBRARY	Fans, Setback HHW		B	5	EMS	EMS	Occ	
HAZ MAT FAC	Fans except EF3 and EF9		B	5	EMS	EMS		
MOSES	FANS, SETBACK HHW		B	5	EMS	EMS		
STEPHENS	FANS, SETBACK HHW		B	5	EMS	EMS		
BLUM HALL	Change fan coil and lighting schedules to unoccupied. EXCEPT FC-19.		A		EMS	EMS	EMS?	
CAMPBELL	VAVs to UNOCCUPIED on all floors EXCEPT Lower Level, and Rooms 325 and 425		A		EMS	Ex		
CHAVEZ	Setback HHW, Fans		A		EMS	EMS		
DOE ANNEX (Bancroft)	TURN OFF LIGHTING (By Library staff)		A		EMS	Ex	Occ	
DURANT	FANS, Mitsubishi units (on/off by EMS), SETBACK HHW		A		EMS	EMS		
ESHLEMAN	Change Occupancy Schedule to unoccupied		A		EMS	EMS		
GREEK THEATR	Fans		A		EMS	N/A		
JACOBS	Fans, HHW Valve		A		EMS	EMS		
KING UNION (MLK)	Fans, Setback HHW. EXCEPT Basement, 1st and 2nd Floors.		A		EMS	EMS		
LE ROY1893 (GSPP)	FANS, BOILER				EMS	EMS		
LATIMER	Add lockout to Chiller @ 66 degrees.							
TAN	Add lockout to Chiller @ 66 degrees.							
WURSTER	FANS AHU-1, 3, 4. EXCEPT AHU-2							
Berkeley Way West	Sunday mode - Unoccupied STARTING WEDNESDAY, 12/23 @ 3:00.							
Golden Bear Café	If possible, change HP and Ltg schedules to unoccupied		A		EMS	n/a		

CORY	Curtail AHU3, AHU4, AC90, AC108/9, Chiller 91 (loop), Chiller 54/55 (loop), SETBACK HHW from 180 deg to 150 deg. EXCEPT AH-1 (rm. 405), *AH-2 (Roof), SF40 (432) SF# 102 (545G Mech.), AC#73, SF17, EF18 Rm. (171M). *Actual construction equipment number may vary. (AH-2 is marked AH-1 & AH-3 is marked AC103). <u>Data Center</u> rm. 165, AC100 & AC101, support equipment CT#1 (roof).		B	2				
EVANS	Fans, Setback HHW		B	2	EMS	EMS		
NORTH GATE	FANS		B	2	EMS	Ex		
SODA	Curtail AHU2, 3, 4 regular; AHU1 and setback HHW		B	2	EMS	EMS		
HAAS FAC BLD	Fans, Setback HHW		A/B	3	EMS	EMS		
Physics North - LeConte Physics Sout - LeConte Annex	LeConte - Change HHW SP control to "optimized" vs OA Reset, AHU1 close 2nd fl damper, AHU2 schedule all HCs on 3rd and 4th floors to unoccupied; Annex - AHU 2,3,4,5		A/B	3			EMS	EMS
MINOR	Fans, Except SF&EFs 1-5		B	3	EMS	Ex		
VALLEY LSB	AHU7, 8, 16, 17, 18, 19, 20, 21. Add Lockout on Chiller to 66.		A/B	4	EMS	Ex		
BARROWS	FANS. Except AHU2 (SF47 EF49) and HX 43 or HX 1&2 (serve AHU2).		A/B	5	EMS	EMS		
DWINELLE	FANS Except SF 13 and EF 16 and LEVEL C , Setback HHW.		B	5	EMS	EMS		
CHEIT	Setback HHW, Fans		A		EMS	EMS		
Chou Hall	Fans, Setback HHW. Unoccupied. EXCEPT Chilled Water Pumps for heat pumps. N019A, N352, N352A, N552, N552A, & N659. N023.		A				EMS	EMS
WHEELER	Fans, Setback HHW, Lighting (Wattstopper)		A		EMS	EMS		Elec
MOFFITT	Fans AHUs 1&2, ROOF EXHAUST FANS, EF37, 38		A		EMS	Ex		
REC SPORTS (closed due to pandemic)	Fans. Setback HX to 140 degrees. Starting Wednesday, 12/23 @ 3:00.							
ZELLERBACH	Fans		B	5	EMS	EMS		