

2020 Holiday Curtailment

Program

Updated: 12/21/20

Shutdown Tuesday, December 22, 2020, 3:00 pm	Startup Monday, January 4, 2021 10:00 am
--	--

Team			
Num	Name	Office*	Cell Number
1	Bruce Chamberlain	EO	510-812-3711
2	Catherine Patton	EO	510-549-6472
3	Kume Wolde	EO	510-292-8100
4	Ahmed Hassani	EO	510-847-3100
5	U Yu Kyi	SE	510-812-2137
6	Raul Abesamis	EMS	510-812-0828
7	David Etayo - ALC	EMS	510-812-2130
8	Bricio Yuriar - Barrington	EMS	510-812-0831
9	Todd McFerren	ELEC	510-812-0853
	TBD	ELEC	

*EO = Energy Office

SE = Stationary Engineer, PM

EMS = Energy Management System

ELEC = Electrical Shop

General Notes:

- 1 Safety first
- 2 Systems supporting fume hood, animal, or temperature controlled operations should NOT be turned off
- 3 **Setback heat exchangers/boilers to 140 degrees (minimum).**
- 4 Field verify that systems can be de-energized and shutdown
- 5 Where variations occur, notify leads and record differences
- 6 Notify leads of system shutdown and startup failures

2020 Holiday Curtailment

Stats

Updated: 12/21/20

Curtailment at regular times								
Building Name	Systems	Notes	EMS	Zone	Fans 19	HHW 19	Ltg 19	
ALUMNI HOUSE	FANS, SETBACK HHW				SE	SE		
BANCROFT 2200	FAN, HEAT, LIGHTING				SE	SE	Elec	
BANCROFT 2401 (Dance Studio)	FANS, ALL HEAT				SE	SE		
CHANNING 2515	Turn Down BOILER, LIGHTING					SE	Elec	
CHANNING 2547	HEATING SYSTEMS, DHW. Boiler pump (panel B, 4)				SE	SE		
Chern (MSRI)	Setback Boiler on roof, via door on 3rd fl north side, to your left on the roof. Facility Coordinator curtailing AHUs and Boilers (half on Trane), lighting.				Occ	SE		
COLLEGE 2251	SE will shut down boiler and setback temperatures				SE	Occ		
DWINELLE AN	FANS, SETBACK STEAM, Setback HEAT, LIGHTING				SE	SE	Elec	
Genetics and Plant Bio	FANS SF-1,2,3,4, EF-5,6,8. Exclude HF9				SE	N/A		
GIAUQUE LAB	Setback HHW to 130 deg if possible				Ex	SE		
GILMAN	Setback HHW to 130 deg if possible				Ex	SE		
HEARST GYM	FANS, POOL Heating,				SE	Ex		
MOFFITT	Fans AHUs 1&2, ROOF EXHAUST FANS, EF37, 38		A		EMS/SE	Ex		
PIEDMONT 2222	SET STATS to LOWEST TEMP, LIGHTING				SE		Elec	
PIEDMONT 2224	SET STATS to LOWEST TEMP (This excludes AC system), LIGHTING				SE		Elec	
PIEDMONT 2232	FURNACE, LIGHTING				SE		Elec	
PIEDMONT 2234	Unoccupied - BOILER, LIGHTING					SE	Elec	
PIEDMONT 2240	SHUTDOWN HHW BOILER, Lighting					SE	Elec	
SILVER SPACE LAB	Shutdown or Setback to 66 degrees CHILLER							
SOUTH	FANS, STEAM RADIATORS, LIGHTING				SE	SE	Elec	